

**NFPA<sup>®</sup>**

# **115**

---

**Standard for  
Laser Fire Protection**

---

**2020**



## IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

### REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo). Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

### REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at [www.nfpa.org](http://www.nfpa.org).

## **ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS**

### **Updating of NFPA Standards**

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at [www.nfpa.org](http://www.nfpa.org).

### **Interpretations of NFPA Standards**

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

### **Patents**

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

### **Law and Regulations**

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

### **Copyrights**

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

### **For Further Information**

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: [stds\\_admin@nfpa.org](mailto:stds_admin@nfpa.org).

For more information about NFPA, visit the NFPA website at [www.nfpa.org](http://www.nfpa.org). All NFPA codes and standards can be viewed at no cost at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo).

Copyright © 2019 National Fire Protection Association®. All Rights Reserved.

## NFPA® 115

### Standard for

## Laser Fire Protection

### 2020 Edition

This edition of NFPA 115, *Standard for Laser Fire Protection*, was prepared by the Technical Committee on Laser Fire Protection. It was issued by the Standards Council on April 10, 2019, with an effective date of April 30, 2019, and supersedes all previous editions.

This edition of NFPA 115 was approved as an American National Standard on April 30, 2019.

### Origin and Development of NFPA 115

In September 1988, a request was received by the NFPA Standards Council to establish a project on laser fire protection. At that time, NFPA documents did not address the fire hazards of lasers. Existing non-NFPA standards addressed other laser hazards (primarily health hazards) but did not adequately address the fire hazards involved. In October 1988, the council published a request for comments on the need for such a project. After reviewing comments submitted, the council approved the establishment of a laser fire protection project in July 1989. The resultant document (designated NFPA 115) was intended to supplement existing NFPA documents and other standards involving lasers. Where a particular hazard, such as a flammable liquid, was appropriately addressed by another NFPA document, that document was referenced.

Lasers can be a significant fire hazard. Class 4 and some Class 3b lasers (classification is from ANSI Z136.1, *Safe Use of Lasers*) are powerful enough that the beam is an ignition hazard. During use, particularly in the medical field, the laser beam is directly adjacent to combustible materials and, in certain clinical procedures, flammable gastrointestinal gases and prepping agents. Fire incidents have occurred when the laser beam has impinged on a material other than the intended target.

Additionally, some lasers use flammable liquids as an integral part of their operation. The flammable liquids are pumped and flow through tubing, which can be quartz or plastic. Both types of tubing are prone to damage, either by breaking or melting, when exposed to a fire. When this occurs, a flammable liquid pool of fire is created.

Materials used to fabricate laser systems are often inappropriate with respect to fire safety. Manufacturers do not always choose component materials with regard to their ignition and heat-release properties. Lasers can involve the use of high-energy power supplies. Motors for use with flammable liquids need to be intrinsically safe or of approved electrical classification.

As part of an ongoing effort to document the fire hazards of lasers, there is a database of fires involving lasers. Documented incidents have occurred in hospitals, research laboratories, and industrial applications. According to the data, most incidents involve the laser beam as the ignition source. Materials ignited include adjacent combustibles as well as components of the laser itself. Other incidents have involved components of the laser overheating or igniting due to a failure of the laser system.

In the 1999 edition of this document, changes were made to conform to the NFPA *Manual of Style*. In addition, many of the references to “flammable” liquids were changed to “ignitable” liquids because the word “flammable” was too restrictive.

In the 2003 edition, the document changed from a recommended practice to a standard. Therefore, the language within the body of the document was changed to enforceable language, and recommendations or advisory information was moved to the annexes.

The 2008 edition was revised to stay current with other NFPA documents. The definitions were updated, and the language was changed where appropriate to add clarity. A new requirement was added, which called for fire training for health care facilitators wherever a patient might come in contact with lasers.

The 2012 edition was updated and definitions were changed in accordance with the NFPA *Glossary of Terms*. The language was clarified for pre-fire planning for staff members to be trained and knowledgeable in emergency procedures.

The 2016 edition was updated with current references and definitions in accordance with the NFPA *Glossary of Terms*. In addition to language revisions to clarify requirements, the list of degraded components that could lead to a fire in the Performance Monitoring section was updated.

The 2020 edition has not been significantly revised. Reference standards were updated to the most current editions. Requirements for fire suppression were revised to clarify the decisions concerning selection and placement in NFPA 10 and, while not required, the laser safety officer has the authority to determine whether other suppression systems or methods are appropriate for the particular laser installation.

**Technical Committee on Laser Fire Protection**

**Sharon S. Gilyeat**, *Chair*  
Koffel Associates, Inc., MD [SE]

**Daniel Capostagno**, SPI Lasers, CA [M]

**Yadin David**, Biomedical Engineering Consultants, LLC, TX [SE]

**Sean Frenette**, Hartford Healthcare, CT [U]

**Daniel J. Hewett**, US Food and Drug Administration, MD [E]

**William J. Pate**, University of Texas Medical Branch, TX [U]

**Gary C. Rosenfield**, RCS Rocket Motor Components, Inc./Survival Laser, Inc., UT [M]

**Fred P. Seeber**, Laser Institute of Technology, NJ [U]

**Ronald W. Woodfin**, TetraTek, Inc./AES Corporation, CO [SE]

**Alternates**

**David M. Hope**, TetraTek Inc. Fire Safety Technologies, TN [SE]  
(Alt. to Ronald W. Woodfin)

**Lauren Schrumppf**, Koffel Associates, MD [SE]  
(Alt. to Sharon S. Gilyeat)

**Jonathan Hart**, NFPA Staff Liaison

*This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.*

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

**Committee Scope:** This Committee shall have primary responsibility for documents on fire protection for laser equipment, including their safe installation, use, and maintenance.

## Contents

<b>Chapter 1 Administration</b> .....	115- 5	8.5 Electrical Requirements. ....	115- 11
1.1 Scope. ....	115- 5	8.6 Training. ....	115- 11
1.2 Purpose. ....	115- 5		
1.3 Application. ....	115- 5	<b>Chapter 9 Reactive Gases</b> .....	115- 11
1.4 Retroactivity. ....	115- 5	9.1 General. ....	115- 11
1.5 Equivalency. ....	115- 5	9.2 Work Practices. ....	115- 11
1.6 Interface with Existing Codes and Standards. ...	115- 5	9.3 Fire Safety. ....	115- 11
		9.4 Facilities and Equipment. ....	115- 11
<b>Chapter 2 Referenced Publications</b> .....	115- 5	9.5 Electrical Requirements. ....	115- 12
2.1 General. ....	115- 5	9.6 Training. ....	115- 12
2.2 NFPA Publications. ....	115- 5		
2.3 Other Publications. ....	115- 5	<b>Chapter 10 Ignitable Liquids Used in Laser Systems ...</b>	115- 12
2.4 References for Extracts in Mandatory Sections. ....	115- 6	10.1 General. ....	115- 12
		10.2 Work Practices. ....	115- 12
<b>Chapter 3 Definitions</b> .....	115- 6	10.3 Fire Safety. ....	115- 12
3.1 General. ....	115- 6	10.4 Facilities and Equipment. ....	115- 12
3.2 NFPA Official Definitions. ....	115- 6	10.5 Electrical Requirements. ....	115- 13
3.3 General Definitions. ....	115- 6	10.6 Large-Volume Ignitable Liquid Systems. ....	115- 13
		10.7 Spill Cleanup. ....	115- 13
<b>Chapter 4 Classification of Lasers</b> .....	115- 8	10.8 Waste Disposal. ....	115- 13
4.1 Classification Methods. ....	115- 8	10.9 Training. ....	115- 13
4.2 Application of Requirements. ....	115- 8	10.10 Maintenance. ....	115- 13
<b>Chapter 5 Evaluation of Laser Beam Ignition Potential</b> .....	115- 8	<b>Chapter 11 Operations/Administration</b> .....	115- 13
5.1 General. ....	115- 8	11.1 Safety Operations and Administration. ....	115- 13
5.2 Factors Affecting Ignition Potential. ....	115- 8	11.2 Housekeeping. ....	115- 14
		11.3 Maintenance and Service. ....	115- 14
<b>Chapter 6 Laser Beam Ignition</b> .....	115- 8	11.4 Training and Education. ....	115- 14
6.1 General. ....	115- 8		
6.2 Before Using Laser. ....	115- 8	<b>Chapter 12 Emergency Preparedness</b> .....	115- 14
6.3 Education. ....	115- 8	12.1 Pre-Fire Planning. ....	115- 14
6.4 Facility. ....	115- 9	12.2 Training. ....	115- 14
		12.3 Fire Brigades. ....	115- 14
<b>Chapter 7 Fire Safety Requirements for Laser Equipment</b> .....	115- 9	12.4 Emergency Shutdown. ....	115- 14
7.1 General. ....	115- 9	12.5 Fire Procedure. ....	115- 14
7.2 Laser Equipment Employing Ignitable Liquids or Flammable Gases. ....	115- 9		
7.3 Materials of Construction. ....	115- 9	<b>Annex A Explanatory Material</b> .....	115- 15
7.4 Laser Equipment Ventilation. ....	115- 9	<b>Annex B Nature of Hazards</b> .....	115- 16
7.5 Alarms and Controls. ....	115- 9	<b>Annex C Education and Training</b> .....	115- 16
7.6 Manuals and Training. ....	115- 10	<b>Annex D Classification of Lasers</b> .....	115- 17
		<b>Annex E Flash Point</b> .....	115- 18
<b>Chapter 8 Flammable Gases</b> .....	115- 10	<b>Annex F Informational References</b> .....	115- 18
8.1 General. ....	115- 10		
8.2 Work Practices. ....	115- 10	<b>Index</b> .....	115- 21
8.3 Fire Safety. ....	115- 10		
8.4 Facilities and Equipment. ....	115- 10		

## NFPA 115

## Standard for

## Laser Fire Protection

2020 Edition

**IMPORTANT NOTE:** This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Standards.” They can also be viewed at [www.nfpa.org/disclaimers](http://www.nfpa.org/disclaimers) or obtained on request from NFPA.

**UPDATES, ALERTS, AND FUTURE EDITIONS:** New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the “List of NFPA Codes & Standards” at [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo). In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

**NOTICE:** An asterisk (\*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [ ] following a section or paragraph indicates material that has been extracted from another NFPA document. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced and extracted publications can be found in Chapter 2 and Annex F.

## Chapter 1 Administration

### 1.1 Scope.

**1.1.1** This document shall provide minimum fire protection requirements for the design, manufacture, installation, and use of lasers and associated equipment.

**1.1.2** Criteria for training for and responding to fire emergencies involving lasers shall be included.

**1.2 Purpose.** This document shall provide requirements intended to prevent or mitigate the effects of fire involving lasers.

**1.3 Application.** This document shall apply to lasers capable of producing a beam ignition hazard, lasers utilizing materials or components presenting a fire hazard, and the areas where such lasers are used.

**1.4 Retroactivity.** The provisions of this standard reflect a consensus of what is necessary to provide an acceptable degree of protection from the hazards addressed in this standard at the time the standard was issued.

**1.4.1** Unless otherwise specified, the provisions of this standard shall not apply to facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of the standard. Where specified, the provisions of this standard shall be retroactive.

**1.4.2** In those cases where the authority having jurisdiction determines that the existing situation presents an unacceptable degree of risk, the authority having jurisdiction shall be permitted to apply retroactively any portions of this standard deemed appropriate.

**1.4.3** The retroactive requirements of this standard shall be permitted to be modified if their application clearly would be impractical in the judgment of the authority having jurisdiction, and only where it is clearly evident that a reasonable degree of safety is provided.

**1.5 Equivalency.** Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this standard.

**1.5.1** Technical documentation shall be submitted to the authority having jurisdiction to demonstrate equivalency.

**1.5.2** The system, method, or device shall be approved for the intended purpose by the authority having jurisdiction.

### 1.6 Interface with Existing Codes and Standards.

**1.6.1** When interface with existing NFPA or other consensus codes and standards occurs, reference shall be made in the text to the appropriate source.

**1.6.2** Due to the unique fire hazards associated with lasers and their operations, this standard shall provide additional fire safety requirements beyond that of other documents.

## Chapter 2 Referenced Publications

**2.1 General.** The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

**2.2 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2018 edition.

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2019 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 2018 edition.

NFPA 55, *Compressed Gases and Cryogenic Fluids Code*, 2020 edition.

NFPA 70®, *National Electrical Code*®, 2020 edition.

NFPA 99, *Health Care Facilities Code*, 2018 edition.

NFPA 101®, *Life Safety Code*®, 2018 edition.

NFPA 600, *Standard on Facility Fire Brigades*, 2020 edition.

NFPA 704, *Standard System for the Identification of the Hazards of Materials for Emergency Response*, 2017 edition.

### 2.3 Other Publications.

**2.3.1 ANSI Publications.** Laser Institute of America, Secretariat of ANSI Z136, 13501 Ingenuity Drive, Suite 128, Orlando, FL 32826 ([www.lia.org](http://www.lia.org)).

ANSI Z136.1, *Safe Use of Lasers*, 2014.



ANSI Z136.3, *Safe Use of Lasers in Health Care Facilities*, 2011.

ANSI Z136.5, *Safe Use of Lasers in Educational Institutions*, 2009.

**2.3.2 ASTM Publications.** ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D5, *Standard Test Method for Penetration of Bituminous Materials*, June 1, 2013.

ASTM D4359, *Standard Test for Determining Whether a Material Is a Liquid or a Solid*, 2012.

**2.3.3 CGA Publications.** Compressed Gas Association, 4221 Walney Road, 5th Floor, Chantilly, VA 20151-2923.

CGA V-1, *Standard for Compressed Gas Cylinder Valve Outlet and Inlet Connections*, 2013.

**2.3.4 IEC Publications.** Available from American National Standards Institute, 25 West 43rd Street, 4th floor, New York, NY 10036, U.S. National Committee for the IEC ([www.ansi.org](http://www.ansi.org)).

IEC 60825-1, *Safety of laser products — Part 1: Equipment classification and requirements*, 2014.

**2.3.5 U.S. Government Publications.** U.S. Government Publishing Office, Superintendent of Documents, Washington, DC 20402.

OSHA Instruction Pub 8-1.7, *Guidelines for Laser Safety and Hazard Assessment*, August 5, 1991.

Title 21, Code of Federal Regulations, Part 1040, Chapter 1, “Performance Standards for Light Emitting Products,” April 1, 2014.

Title 21, Code of Federal Regulations, Parts 1040.10 and 1040.11, April 1, 2013.

Title 29, Code of Federal Regulations, Part 1910.38(b)(4)(i).

Title 40, Code of Federal Regulations.

Title 49, Code of Federal Regulations.

### 2.3.6 Other Publications.

*Merriam-Webster's Collegiate Dictionary*, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

### 2.4 References for Extracts in Mandatory Sections.

NFPA 30, *Flammable and Combustible Liquids Code*, 2018 edition.

NFPA 53, *Recommended Practice on Materials, Equipment, and Systems Used in Oxygen-Enriched Atmospheres*, 2016 edition.

NFPA 59A, *Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)*, 2019 edition.

NFPA 99, *Health Care Facilities Code*, 2018 edition.

NFPA 306, *Standard for the Control of Gas Hazards on Vessels*, 2019 edition.

NFPA 600, *Standard on Facility Fire Brigades*, 2015 edition.

NFPA 921, *Guide for Fire and Explosion Investigations*, 2017 edition.

## Chapter 3 Definitions

**3.1 General.** The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

### 3.2 NFPA Official Definitions.

**3.2.1\* Approved.** Acceptable to the authority having jurisdiction.

**3.2.2\* Authority Having Jurisdiction (AHJ).** An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

**3.2.3 Labeled.** Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

**3.2.4\* Listed.** Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

**3.2.5 Shall.** Indicates a mandatory requirement.

**3.2.6 Should.** Indicates a recommendation or that which is advised but not required.

**3.2.7 Standard.** An NFPA Standard, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase “standards development process” or “standards development activities,” the term “standards” includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

### 3.3 General Definitions.

**3.3.1\* Accessible Emission Limit (AEL).** The maximum accessible emission level permitted within a particular class.

**3.3.2\* Beam.** A collection of rays that can be parallel, divergent, or convergent.

**3.3.3 Beam Intensity Profile (Irradiance Distribution).** A description of the variations that can be present in the cross-section of a laser beam or in a focused laser spot.

**3.3.4\* Continuous Wave (cw).** The output of a laser operated in a continuous rather than a pulsed mode.

**3.3.5\* Energy.** The capacity for doing work.

**3.3.6\* Explosion.** The sudden conversion of potential energy (chemical, mechanical, or nuclear) into kinetic energy that produces and violently releases gas.

**3.3.7 Facility Fire Brigade.** An organized group of employees at a facility who are knowledgeable, trained, and skilled in at least basic fire-fighting operations, and whose full-time occupation might or might not be the provision of fire suppression and related activities for their employer. [600, 2015]

**3.3.8\* Flammable Liquid Storage Cabinet.** A cabinet for the storage of flammable and combustible liquids.

**3.3.9 Flammable Vapors.** A concentration of constituents in air that exceeds 25 percent of its lower flammable limit (LFL).

**3.3.10\* Flash Point.** The minimum temperature at which a liquid or a solid emits vapor sufficient to form an ignitable mixture with air near the surface of the liquid or the solid.

**3.3.11 Gas.**

**3.3.11.1 Compressed Gas.** Any material or mixture having, when in its container, an absolute pressure exceeding 40 psi (an absolute pressure of 276 kPa) at 21.1°C (70°F) or, regardless of the pressure at 21.1°C (70°F), having an absolute pressure exceeding 104 psi (an absolute pressure of 717 kPa) at 54.4°C (130°F).

**3.3.11.2 Flammable Gas.** Any substance that exists in the gaseous state at normal atmospheric temperature and pressure and is capable of being ignited and burned when mixed with the proper proportion of air, oxygen, or other oxidizers. [99, 2018]

**3.3.11.3\* Reactive Gas.** A gas that, by itself, is readily capable of detonation, explosive decomposition, or explosive reaction at normal or elevated temperatures and pressures.

**3.3.12\* Hazardous Chemical.** A chemical with one or more of the following hazard ratings as defined in NFPA 704: Health — 2, 3, or 4; Flammability — 2, 3, or 4; Reactivity — 2, 3, or 4.

**3.3.13 Irradiance.** The power of a laser divided by the area of the laser beam at the target surface, expressed in watts per centimeter squared (W/cm<sup>2</sup>).

**3.3.14\* Joule.** The preferred SI unit of heat, energy, or work. [921, 2017]

**3.3.15 Laboratory Apparatus.** Furniture, laboratory hoods, centrifuges, refrigerators, and commercial or made-on-site equipment used in a laboratory.

**3.3.16\* Laser.** A device that produces an intense, coherent, directional beam of light by stimulating electronic or molecular transitions to lower energy levels (an acronym for Light Amplification by Stimulated Emission of Radiation).

**3.3.16.1 Embedded Laser.** An enclosed laser with an assigned class number higher than the inherent capability of the laser system in which it is incorporated, where the system's lower classification is appropriate due to the engineering features limiting accessible emission.

**3.3.16.2 Pulsed Laser.** A laser that delivers its energy in the form of a single pulse or a train of pulses; a single pulse or a train of pulses with a pulse duration of <0.25 second.

**3.3.16.3 Q-Switched Laser.** A laser that emits short (approximately 10 to 250 nanoseconds), high-power pulses by means of a Q-switch.

**3.3.17\* Laser Safety Personnel (LSP).** One who has authority to monitor and enforce the control of laser hazards and to effect the knowledgeable evaluation and control of laser hazards.

**3.3.18\* Laser System.** An assembly of electrical, mechanical, and optical components that includes a laser.

**3.3.19 Lecture Bottle.** A small compressed gas cylinder with a physical volume of less than 500 cm<sup>3</sup>.

**3.3.20 Liquid.** Any material that (1) has a fluidity greater than that of 300 penetration asphalt when tested in accordance with ASTM D5, *Standard Test Method for Penetration of Bituminous Materials*, or (2) is a viscous substance for which a specific melting point cannot be determined but that is determined to be a liquid in accordance with ASTM D4359, *Standard Test for Determining Whether a Material Is a Liquid or a Solid*. [30, 2018]

**3.3.20.1 Combustible Liquid.** Any liquid that has a closed-cup flash point at or above 37.8°C (100°F). [306, 2019]

**3.3.20.1.1 Combustible Liquid, Class II.** Any liquid that has a flash point at or above 100°F (37.8°C) and below 140°F (60°C). [30:4.3.2]

**3.3.20.1.2 Combustible Liquid, Class IIIA.** Any liquid that has a flash point at or above 140°F (60°C), but below 200°F (93°C). [30:4.3.2]

**3.3.20.1.3 Combustible Liquid, Class IIIB.** Any liquid that has a flash point at or above 200°F (93°C). [30:4.3.2]

**3.3.20.2 Flammable Liquid.** A liquid that has a closed-cup flash point that is below 37.8°C (100°F) and a maximum vapor pressure of 2068 mm Hg (absolute pressure of 40 psi) at 37.8°C (100°F)

**3.3.20.2.1 Flammable Liquid Class I.** Any liquid that has a closed-cup flash point below 37.8°C (100°F) and a Reid vapor pressure not exceeding 2068.6 mm Hg (absolute pressure of 40 psi) at 37.8°C (100°F).

**3.3.20.2.2 Flammable Liquid Class IA.** Any liquid that has a flash point below 22.8°C (73°F) and a boiling point below 37.8°C (100°F).

**3.3.20.2.3 Flammable Liquid Class IB.** Any liquid that has a flash point below 22.8°C (73°F) and a boiling point at or above 37.8°C (100°F).

**3.3.20.2.4 Flammable Liquid Class IC.** Any liquid that has a flash point at or above 22.8°C (73°F), but below 37.8°C (100°F).

**3.3.20.3 Ignitable Liquid.** Any liquid or the liquid phase of any material that is capable of fueling a fire, including a flammable liquid, combustible liquid, or any other material that can be liquefied and burn.

**3.3.21 Lower Explosive Limit or Lower Flammable Limit.** The minimum concentration of combustible vapor or combustible gas in a mixture of the vapor or gas and gaseous oxidant above

which propagation of flame will occur on contact with an ignition source.

**3.3.22\* Maintenance (Laser Products).** Performance by the user of those adjustments or procedures specified in user information provided by the manufacturer with the laser or laser system to ensure the intended performance of the product.

**3.3.23\* Maximum Allowable Working Pressure.** The maximum gauge pressure permissible at the top of completed equipment, a container, or a vessel in its operating position for a design temperature. [59A, 2019]

**3.3.24\* Noncombustible.** Not capable of igniting and burning when subjected to a fire.

**3.3.25\* Operation.** The performance of the laser or laser system over the full range of its intended functions (normal operation).

**3.3.26 Oxidizing Material.** Any material that readily yields oxygen or other oxidizing gas or that reacts chemically to oxidize combustible materials.

**3.3.27 Oxygen-Enriched Atmosphere (OEA).** An atmosphere in which the concentration of oxygen exceeds 21 percent by volume or its partial pressure exceeds 21.3 kPa (160 torr). [53, 2016]

**3.3.28\* Plasma.** A state of ionization in a gas, solid, or liquid that can be generated by the very high electromagnetic field strengths of focused laser beams or by the impact of high-power laser beams.

**3.3.29 Power.** The rate at which energy is emitted, transferred, or received; the units of power are watts (joules/second).

**3.3.30 Proper(ly).** In accordance with the manufacturer's specifications or as recommended by the manufacturer.

**3.3.31\* Protective Housing.** An enclosure that surrounds the laser or laser system that prevents access to laser radiation above the applicable maximum permissible exposure (MPE) level.

**3.3.32\* Q-Switch.** A device for producing very short (approximately 30 nanoseconds), intense laser pulses by enhancing the storage and dumping of electronic energy in and out of the lasing medium, respectively.

**3.3.33\* Radiant Exposure.** Energy received by the surface in joules/cm<sup>2</sup>.

**3.3.34 Safety Factor.** The ratio of the calculated failure pressure (or actual failure pressure, if known) to the MAWP.

**3.3.35\* Service (Laser Products).** The performance of those procedures or adjustments described in the manufacturer's service instructions that can affect any aspect of the performance of the laser or laser system.

**3.3.36 Watt (W).** Unit of power, or rate of work, equal to one joule per second, or the rate of work represented by a current of one ampere under the potential of one volt. [921, 2017]

## Chapter 4 Classification of Lasers

**4.1 Classification Methods.** Lasers shall be classified in accordance with International Electrotechnical Commission

(IEC) IEC 60825-1, *Safety of laser products — Part 1: Equipment classification, requirements and user's guide*, or 21 CFR Parts 1040.10 and 1040.11. (See Annex D.)

**4.2 Application of Requirements.** The fire protection requirements provided within this standard shall apply to the following classification of lasers:

- (1) Class 3b
- (2) Class 4

## Chapter 5 Evaluation of Laser Beam Ignition Potential

### 5.1 General.

**5.1.1\*** Continuous wave (cw) laser beams producing irradiances in the order of 0.5 W/cm<sup>2</sup> or greater shall be considered to be ignition hazards.

**5.1.2** Other factors that shall be considered with pulsed lasers include the following:

- (1) Radiant exposure
- (2) Pulse duration
- (3)\* Pulse repetition rate

**5.1.3** Class 4 lasers shall always be considered to be beam ignition hazards.

**5.1.4\*** Lasers in the upper power and energy levels of Class 3b shall be considered as beam ignition hazards if the irradiance is greater than 0.5 W/cm<sup>2</sup>.

**5.2 Factors Affecting Ignition Potential.** Factors affecting ignition potential shall include the following:

- (1) Irradiance at the fuel, duration of exposure, and nature of the fuel
- (2) Low irradiance laser beams capable of being focused to an irradiance sufficient to cause ignition
- (3) Irradiance and the exposure time at the target
- (4) Oxygen-enriched atmospheres
- (5) Target thickness
- (6) Irradiance modalities capable of generating plasma

## Chapter 6 Laser Beam Ignition

**6.1 General.** Before a laser is used, the alignment shall be verified, the appropriate beam stop materials shall be in place, and the facility, control measures, safety, and training programs shall be established in accordance with ANSI Z136.1, *Safe Use of Lasers*.

### 6.2 Before Using Laser.

**6.2.1 Beam Alignment.** If an alignment beam is present, proper coincidence with the treatment beam shall be verified in accordance with the manufacturer's recommendations.

**6.2.2 Beam Stop Materials.** Before the laser is used, it shall be determined that the appropriate beam stop materials are in place.

### 6.3 Education.

#### 6.3.1 Health Care.

**6.3.1.1** Education shall be in accordance with that stated in ANSI Z136.3, *Safe Use of Lasers in Health Care Facilities*.

**6.3.1.2\*** Detailed training in laser safety shall be required for those health care personnel who use a medical laser or are responsible for patient care during the use of a medical laser.

**6.3.1.3** Training shall include extinguishing laser fires when a patient is directly involved in a laser fire event.

**6.3.2 Other.** Education shall be in accordance with that stated in ANSI Z136.1, *Safe Use of Lasers*.

#### 6.4 Facility.

**6.4.1** Health care facilities where laser systems are used shall comply with the following:

- (1) ANSI Z136.3, *Safe Use of Lasers in Health Care Facilities*
- (2) NFPA 101, for detection, suppression, and means of egress
- (3) NFPA 99, for electrical systems, electrical equipment, gas and vacuum systems, and gas equipment

**6.4.2 Other.** Facilities where laser systems are used shall comply with the following:

- (1) ANSI Z136.1, *Safe Use of Lasers*
- (2) NFPA 101, for detection, suppression, and means of egress
- (3) NFPA 70

#### 6.4.3 Flammable and Combustible Conditions.

**6.4.3.1** Nothing shall be considered fire safe when impinged upon by a laser beam in the presence of an oxygen-enriched atmosphere, except for the noble metals.

**6.4.3.2** Potential fuels shall include, but not be limited to, the categories listed in 6.4.3.2.1 and 6.4.3.2.2.

**6.4.3.2.1** Health care categories shall include the following:

- (1) *Patients.* Hair, gastrointestinal gases (methane, hydrogen, and hydrogen sulfide)
- (2) *Prepping Agents.* Degreasers (ether, acetone, aerosol adhesives, alcohol), tinctures (Hibitane™, Merthiolate™, collodion, benzoin)
- (3) *Fabric Products.* Towels, surgical drapes, dressings, gowns, masks, shoe covers, caps/hoods, gauze, sponges, patient warming devices
- (4) *Plastic/Rubber Products.* Surgical drapes, gloves, anesthesia masks, tracheal tubes, breathing circuits, patient warming devices
- (5) *Ointments.* Petroleum-based jelly
- (6) *Laser Circuitry.* Beam tubes, fiber-optic cables

**6.4.3.2.2** Gas categories shall include the following:

- (1) *Flammable Gases.* Flammable gastrointestinal gases such as methane, hydrogen, and hydrogen sulfide present a unique hazard. Precautions to eliminate or manage these gases shall be taken.
- (2) *Oxidizing Gases.* Ignition can be enhanced by the use of oxygen-enriched atmospheres that are created by the use of respiratory or anesthetic gases, or both — for example, oxygen and nitrous oxide.
- (3) *Nonflammable Gases.* Nonflammable anesthetic gases and vapors have replaced flammable anesthetic gases and vapors in the United States.

## Chapter 7 Fire Safety Requirements for Laser Equipment

**7.1 General.** Selection of materials used in the construction of the laser shall include consideration of fire safety requirements for the following:

- (1) Circuit boards and support structures
- (2) Acoustical, thermal, and electrical insulation
- (3) Cabinetry
- (4) Cooling equipment
- (5) Control equipment

### 7.2 Laser Equipment Employing Ignitable Liquids or Flammable Gases.

**7.2.1** Laser equipment employing ignitable liquids shall have a means to control or contain ignitable liquid spills using noncombustible materials.

**7.2.2** When ignitable solvents are used, such as in dye lasers, products with the highest possible flash point consistent with the necessary solvent properties shall be used.

**7.2.3** Laser equipment having oil-cooled components shall employ a nonflammable fluid or a fluid with the highest flash point and ignition temperature that is consistent with the necessary coolant properties.

**7.2.4\*** Pumps, motors, and other electrical components in laser equipment that employ ignitable liquids or flammable gases shall be of intrinsically safe design or shall be appropriately rated for the application.

### 7.2.5 Tubing.

**7.2.5.1** Metal tubing shall be used for ignitable liquids or flammable gases.

**7.2.5.2** Plastic tubing shall be permitted provided it has a pressure rating of 1.5 times the maximum allowable working pressure, be of a material with the highest melting point and ignition temperature consistent with other necessary properties, and be of the shortest length possible.

### 7.3\* Materials of Construction.

**7.3.1** The use of combustible materials shall be minimized.

**7.3.2** Materials used inside the laser equipment enclosure shall be evaluated for ignition and heat release properties.

**7.4 Laser Equipment Ventilation.** Exhaust from laser enclosures shall be directed to an area where the exhaust will not cause unacceptable damage if a fire occurs inside the laser enclosure.

### 7.5 Alarms and Controls.

#### 7.5.1 Circuits.

**7.5.1.1** Laser systems utilizing materials and components that present a fire hazard shall incorporate circuitry that can be used for emergency shutdown by fire detection systems, manually, or by other means.

**7.5.1.2** The design of the circuit shall not permit automatic restart with restoration of power following a remote shutdown.

**7.5.1.3** The design of the circuit shall not allow automatic restart until the fire detection system or manual alarm system has been reset.

## 7.5.2 Coolants and Ignitable Liquids.

**7.5.2.1** The temperature of coolants and ignitable liquids shall be monitored to warn of excessive rate of heating or approach to threshold temperature.

**7.5.2.2** Provisions shall be made for alarm and automatic shutdown should such conditions be detected.

### 7.5.3\* Monitors.

**7.5.3.1** The laser equipment cabinet or exhaust shall be monitored for the presence of pre-combustion products, such as hydrogen chloride or submicron particulate, that can be produced by component overheating or from products of combustion.

**7.5.3.2** Multiple alarm thresholds such as “warning,” “alarm,” and “automatic shutdown” shall be considered.

### 7.5.4 Performance Monitoring.

**7.5.4.1** Degradation of components that lead to a fire shall be monitored according to parameters that shall include one or more of the following:

- (1) Component temperature
- (2) Device electrical parameters (current, voltage)
- (3) Laser power
- (4) Frequency or magnitude of power excursions
- (5) Light leakage or scatter

**7.5.4.2** The monitoring function shall be accomplished by automatic or manual means at time intervals determined by the manufacturer.

## 7.6 Manuals and Training.

**7.6.1** Fire safety features and fire hazards specific to the systems shall be included in manufacturers’ instructions on laser system operations.

**7.6.2** Manufacturers’ instructions shall provide guidance for dealing with fire emergencies and the post-fire testing and restoration of the equipment.

**7.6.3** Laser system users and service staff shall be trained on the laser system fire safety features and procedures for responding to fire emergencies prior to the user’s first use and shall continue ongoing training in accordance with ANSI Z136.1, *Safe Use of Lasers*.

## Chapter 8 Flammable Gases

### 8.1 General.

**8.1.1** The general requirements of NFPA 55 shall be followed.

**8.1.2** To determine if a gas is flammable, the rating as listed in CGA V-1, *Standard for Compressed Gas Cylinder Valve Outlet and Inlet Connections*, shall be used.

### 8.2 Work Practices.

**8.2.1** Laser systems utilizing or containing flammable gas(es) shall be so labeled.

**8.2.2** Gas shutdown capability shall be provided both at the location of use and remotely.

**8.2.3** “Flammable Gas — No Smoking” signs shall be posted conspicuously near the supply and usage locations of the flammable gases.

**8.2.4** Piping for flammable gases shall be capped when not in use.

**8.2.5** No modifications shall be made to pressure containers or pressure relief devices by anyone except the supplier.

**8.2.6** Systems shall be regularly maintained as recommended by the manufacturer.

### 8.3 Fire Safety.

**8.3.1** Combustible gas sensors shall be located near the area of use of the flammable gases except where demonstrated by calculation that 25 percent of the lower explosive limit (LEL) cannot be reached if the entire contents were to discharge.

**8.3.2** If the supply of flammable gases is located indoors, combustible gas sensors shall be used except where demonstrated by calculation that 25 percent of the LEL cannot be reached if the entire contents were to discharge.

**8.3.3** When installed, combustible gas sensors shall be interlocked with the ventilation system and the exhaust ventilation increased at 25 percent of the LEL.

**8.3.4** At 25 percent of the LEL, combustible gas sensors shall sound an audible alarm.

**8.3.5** At 50 percent of the LEL, the combustible gas sensors shall sound an audible alarm and automatically shut off the supply of gases.

### 8.4 Facilities and Equipment.

#### 8.4.1 General.

**8.4.1.1** Indoor cylinder use shall be limited to lecture bottle size unless the cylinder(s) is kept in an approved ventilated cabinet or the room is provided with sufficient ventilation to keep the gas concentration below 25 percent of the LEL if the entire contents of the cylinder(s) in use were to discharge.

**8.4.1.2\*** Outside flammable gas supplies in excess of 11.3 m<sup>3</sup> (400 ft<sup>3</sup>) shall be separated from oxidizing gases by 6.1 m (20 ft) or a 2-hour fire-rated barrier.

#### 8.4.1.3 Flammable Gas Supplies.

**8.4.1.3.1** Exterior flammable gas supply capacity shall be evaluated so as to not exceed combustibility limits if accidentally released into any closed area where supply gas lines are routed.

**8.4.1.3.2** Evaluation of closed areas where combustible gas mixtures might occur shall include assessments of installed ventilation system air exchange rates and exhaust systems, if present.

**8.4.1.3.3** Combustible gas sensors shall be installed in enclosed areas where flammable gases could exceed combustibility limits.

**8.4.1.3.4** A combustible gas sensor alarm shall shut off the gas supply at the source and vent the gas supply lines from the enclosed area(s) to a safe location.

**8.4.1.3.5** General air dynamics within the closed areas shall be evaluated for determination of location for combustible gas sensors.

**8.4.1.4 Exhaust Vents.**

**8.4.1.4.1** Exhaust vents shall be located at least 15.3 m (50 ft) away from air intakes for hydrogen and at least 7.6 m (25 ft) for other exhaust materials.

**8.4.1.4.2** When venting above a roof, piping shall be high enough to mitigate the chance of flammable gas buildup in an undesirable location.

**8.4.2 Piping.**

**8.4.2.1** Piping shall be clean and compatible with the gas.

**8.4.2.2** Piping shall be designed to a safety factor of 4 and tested to 1.5 times the MAWP.

**8.4.2.3** Piping shall be pressure-tested and then leak-checked prior to initial use and after repair and modification.

**8.4.2.4** Flammable gas vent lines shall be dedicated and separate from oxidizing gas vent lines and shall terminate in a safe location.

**8.4.3\* Regulators.**

**8.4.3.1\*** Flammable gas regulators with bonnet fittings for piping external venting shall be used in enclosed areas.

**8.4.3.2** If low pressures are required, a two-stage regulator shall be used.

**8.4.3.3 Flow Control.**

**8.4.3.3.1** A flow control valve or a supplementary valve downstream of the regulator shall be used for control of flow.

**8.4.3.3.2** The regulator shall not be used as a flow control.

**8.5 Electrical Requirements.** Electrical circuits, devices, fixtures, and grounding in the area of a laser classified as hazardous and for direct connection of the laser shall be installed in accordance with the applicable sections of *NFPA 70*.

**8.6 Training.**

**8.6.1** A thorough training program in emergency procedures shall be provided for all staff members working with flammable gases.

**8.6.2** The training program shall include drills, fire protection features awareness, coordination with fire-fighting personnel, and knowledge of remote shutoff for gases.

**Chapter 9 Reactive Gases**

**9.1 General.** The general requirements of *NFPA 55* shall be followed.

**9.2 Work Practices.**

**9.2.1** The reactive gas system shall be labeled to identify its contents.

**9.2.2** Gas shutdown capability shall be provided both at the location of use and remotely.

**9.2.3** Where possible, the gas cabinet shall be located outdoors.

**9.2.4** When not in use, compressed gas cylinders containing reactive gases shall be capped.

**9.2.5** When connecting or disconnecting bottles, the manifold system shall be purged to minimize the effect of corrosion of the system.

**9.2.6 Maintenance.**

**9.2.6.1** Systems shall be maintained regularly as recommended by the manufacturer.

**9.2.6.2** A system data package, including a maintenance log, shall be maintained.

**9.2.6.3** The data package shall include installed exhaust calibration data.

**9.2.7** Reactive gases cylinders shall be located in an approved ventilated cabinet consistent with *NFPA 55*.

**9.2.8** No modifications shall be made to pressure containers or pressure relief devices except as authorized by the supplier.

**9.3 Fire Safety.**

**9.3.1** Written procedures shall be followed for cylinder changing and maintenance.

**9.3.2** A limiting orifice shall be installed on each cylinder to limit the release rate of the gas.

**9.3.3\* Gas Cabinets.**

**9.3.3.1** Gas cabinets shall be provided with a sprinkler system inside of the cabinet and shall be protected from corrosion where necessary.

**9.3.3.2** Sprinkler installation shall comply with *NFPA 13*.

**9.3.4 Gas Quantity and Concentration.**

**9.3.4.1** Only the smallest quantity or percent of reactive gas necessary shall be used.

**9.3.4.2** Premixed gases shall be used to minimize the need for highly concentrated reactive gases.

**9.3.5** The regulator chosen for use shall be compatible with the reactive gas.

**9.4 Facilities and Equipment.****9.4.1 General.**

**9.4.1.1** When the ventilated cabinet is located indoors, connecting the cabinet to emergency power shall be considered to ensure continued exhaust capability.

**9.4.1.2** Laser system exhaust shall be diluted to below reactive levels or mixed with an inert gas.

**9.4.1.3** Exhaust systems shall be designed to ensure that the exhaust does not stagnate in exhaust piping.

**9.4.1.4** The supply control valve shall be a solenoid valve designed to close in the event of loss of electrical power.

**9.4.1.5 Exhaust.**

**9.4.1.5.1** The piping exhaust shall be located at least 7.6 m (25 ft) away from air intakes.

**9.4.1.5.2** When venting above a roof, piping shall be high enough to minimize the possibility of reactive gas buildup in an undesirable location.

## 9.4.2 Piping.

9.4.2.1 Piping shall be clean and compatible with the gas.

9.4.2.2 Piping shall be designed to a safety factor of 4 and tested to 1.5 times the MAWP.

9.4.2.3 Piping shall be pressure-tested and leak-checked prior to initial use and after repair and modification.

9.4.2.4\* Piping shall be purged with an inert gas during long periods of nonuse, maintenance, or servicing.

### 9.4.2.5 Fittings.

9.4.2.5.1 “Face-seal”-type fittings shall be considered acceptable.

9.4.2.5.2\* Threaded or compression fittings shall not be used.

9.4.2.6 Traps or check valves shall be installed if there is the possibility of system contamination by other gases or foreign material.

## 9.4.3 Regulators.

9.4.3.1 Vents from regulators shall be piped to a safe location.

9.4.3.2 When low pressures are required, a two-stage regulator shall be used.

9.4.3.3 Regulator diaphragm failures shall be considered when locating a reactive gas regulator in an enclosed area.

9.4.3.4\* Reactive gas regulators with bonnet fittings for piping external venting shall be used in enclosed areas.

9.4.3.5 Vents shall be piped to a safe location.

## 9.4.4 Flow Control.

9.4.4.1 A flow control valve or a supplementary valve downstream of the regulator shall be used for control of flow.

9.4.4.2 The regulator shall not be used as a flow control.

**9.5 Electrical Requirements.** Electrical circuits, devices, fixtures, and grounding in the area of a laser classified as hazardous and for direct connection of the laser shall be installed in accordance with the appropriate sections of *NFPA 70*.

## 9.6 Training.

9.6.1 A thorough training program in emergency procedures shall be provided for all staff members working with reactive gases.

9.6.2 The training program shall include drills, fire protection features awareness, coordination with fire-fighting personnel, and knowledge of remote shutoff for gases.

## Chapter 10 Ignitable Liquids Used in Laser Systems

**10.1\* General.** The requirements of this chapter shall be followed to minimize the risk of fire involving ignitable liquids.

### 10.2 Work Practices.

10.2.1 Signs such as “Caution: Flammable Liquids — No Smoking; No Open Flames” shall be posted in conspicuous locations in the area and at approaches to the area.

10.2.2 Lines (piping and tubing) containing flammable or combustible liquid shall be capped when not in use.

### 10.2.3 Flammable Liquids.

10.2.3.1 Containers of flammable liquids shall be closed and stored in a cool place.

10.2.3.2 Secondary containment for all flammable liquids shall be provided.

10.2.3.3 Each container and the flammable liquid circulation hardware shall have a label that includes the word “flammable.”

10.2.4 Ignitable liquid dye solutions shall be transported in closed, labeled containers made of impact-resistant and dye solution-compatible materials.

10.2.5 Flammable and combustible liquids that are to be dispensed shall be stored in safety cans as described in NFPA 30, Chapter 9.

### 10.3 Fire Safety.

10.3.1 Solutions of ignitable liquids shall be kept away from heat, flames, electrical receptacles, and other sources of ignition.

10.3.2 Oxidizing materials shall be kept separate from flammable dye mixtures and ignitable liquids.

### 10.3.3 Waste Containment.

10.3.3.1 Flammable and combustible liquid waste shall be stored in wide-mouthed safety cans.

10.3.3.2 Containers shall be labeled “For Flammable Liquid Waste Only.”

10.3.3.3 Hazardous (flammable, combustible, and corrosive) materials shall be collected and stored pursuant to 40 CFR and 49 CFR.

### 10.3.4 Cabinets.

10.3.4.1 Flammable- and combustible-liquid containers shall be stored in approved flammable liquid storage cabinets.

10.3.4.2 Only a working quantity of liquids shall be allowed outside such cabinets.

10.3.5 Ventilation shall be provided to prevent a buildup of ignitable vapor/air mixtures in excess of 25 percent of the LEL in areas where flammable liquids are used.

10.3.6\* Equipment or activities likely to produce a static spark shall be electrically interconnected (i.e., bonded) to the grounding system in the area.

## 10.4 Facilities and Equipment.

### 10.4.1 Ignitable Liquid Dye Work Area.

10.4.1.1 The ignitable liquid dye work area shall be kept clean and orderly to minimize the fuel paths that facilitate the spread of fire.

10.4.1.2 Combustibles shall not be located adjacent to the dye circulator pump.

10.4.2 Ignitable liquid dye circulating systems shall be leak-tight.

10.4.3 Compression-type or clamped fittings shall be used for ignitable liquid lines.

#### 10.4.4 Circulating Systems.

**10.4.4.1** Ignitable liquid circulating systems and components shall be pressure tested to 1.5 times the MAWP prior to initial use.

**10.4.4.2** Special attention shall be given to tubing connections.

**10.4.4.3** The integrity of all tubing and connections shall be checked to ensure that degradation has not occurred.

**10.4.5** Noncombustible containment pans shall be installed under pumps and reservoirs of sufficient capacity to contain the total volume of the ignitable liquid circulating system.

**10.5 Electrical Requirements.** Electrical circuits, devices, fixtures, and grounding in the area of a laser classified as hazardous and for direct connection of the laser shall be installed in accordance with the applicable sections of *NFPA 70*.

#### 10.6 Large-Volume Ignitable Liquid Systems.

**10.6.1** Where large-volume ignitable liquid systems [18.9 L (5 gal) or more] are used, *NFPA 30*, shall be followed.

**10.6.2** Pressure sensors, flow sensors, or both, shall be installed to automatically turn off the circulating pumps in the event of a rupture or leak of the flow system.

**10.6.3** Liquid level sensors shall be installed on the pump reservoir to detect a decrease in system liquid volume due to leak or rupture and shall be interlocked with the pumping system to shut down upon activation of the sensors.

**10.6.4** Enclosed areas shall be ventilated at a rate sufficient to maintain the vapor concentration within the area at or below 25 percent of the LEL, confirmed by one of the following methods:

- (1) Calculations based on the anticipated fugitive emissions as described in *NFPA 30*, Annex F
- (2) Sampling of the actual vapor concentration under normal operating conditions as described in *NFPA 30*, Chapters 6, 17, and 18

**10.6.5** Combustible vapor sensors shall be interlocked with exhaust ventilation and with the pumping system.

**10.6.5.1** The exhaust ventilation shall switch to high speed at 25 percent of the LEL to prevent the buildup of flammable vapor concentrations.

**10.6.5.2** At 50 percent of the LEL, an alarm shall sound, and the pumping system shall shut down.

**10.6.6** A liquid detection device(s) shall be installed to detect leaks or spills within laser enclosures.

#### 10.6.7 Remote Shutdown.

**10.6.7.1** Remote shutdown capability for the laser pumping system (i.e., crash buttons) shall also be provided for personnel to activate in case of emergency.

**10.6.7.2** The crash buttons shall be located near main exits of the area.

#### 10.6.8 Building Construction.

**10.6.8.1** Buildings or structures housing large-volume flammable liquid systems shall be of fire-resistive or noncombustible construction.

**10.6.8.2** Combustible construction shall be permitted where automatic fire sprinklers or equivalent protection is provided, subject to the approval of the authority having jurisdiction.

**10.6.8.3** Where walls are required for separation from other occupancies or property lines, they shall have a fire resistance rating of at least 2 hours consistent with the requirements of *NFPA 30*.

#### 10.7 Spill Cleanup.

**10.7.1** Ignitable liquid spills shall be mitigated pursuant to 40 CFR.

**10.7.2** In the event of a large-volume ignitable liquid spill, the fire department shall be notified.

**10.8\* Waste Disposal.** Ignitable liquids absorbed into solids, objects contaminated with ignitable liquids, and ignitable liquid dye solutions shall be managed as hazardous waste pursuant to 40 CFR.

#### 10.9 Training.

**10.9.1** Employees shall be apprised of the fire safety hazards of the materials and processes to which they are exposed. [See *29 CFR 1910.38(b)(4)(i)*.]

**10.9.2** Employees shall review upon initial assignment those parts of the fire prevention plan and the procedures necessary to protect themselves in the event of an emergency.

**10.9.3** The written fire prevention plan shall be kept in the workplace and made available for employee review.

#### 10.10 Maintenance.

**10.10.1** All equipment shall be maintained in accordance with manufacturers' instructions.

**10.10.2** A safety inspection schedule for those portions of laser systems that could present a fire hazard shall be established.

**10.10.3** A written log of these inspections shall be maintained.

## Chapter 11 Operations/Administration

### 11.1 Safety Operations and Administration.

**▲ 11.1.1 Lasers.** Lasers and laser systems shall be operated and maintained in accordance with the following documents:

- (1) ANSI Z136.1, *Safe Use of Lasers*, revised
- (2) ANSI Z136.3, *Safe Use of Lasers in Health Care Facilities*
- (3) Occupational Safety and Health Administration (OSHA) Instruction Pub 8-1.7
- (4) *NFPA 99*, pertaining to electrical systems, electrical equipment, gas and vacuum systems, and gas equipment
- (5) State rules and standards

**11.1.2 Laser Safety Officer (LSO).** Where lasers presenting a fire hazard are used, specific personnel shall be designated to monitor and enforce the control of laser hazards and effect the knowledgeable evaluation and control of laser hazards.

#### 11.1.3 Laser Modifications.

**11.1.3.1** Modifications to certified or uncertified lasers shall meet all requirements of the minimum standards and shall be reviewed and approved by the LSO.



**11.1.3.2** Whenever deliberate modifications are made that could change the laser class and affect the output power, operating characteristics, or fire hazards, the LSO shall specify whether any changes in control measures are required.

#### △ 11.1.4 Fire Suppression.

**11.1.4.1** Portable fire extinguishers shall be provided to extinguish a fire occurring within the laser equipment and as a result of the laser beam.

**11.1.4.2** The selection, placement, and maintenance of portable fire extinguishers shall be in accordance with NFPA 10.

△ **11.1.4.3** The LSO shall determine the need for alternative extinguishers and suppression methods necessary for the specific laser installation(s).

**11.1.4.4** Training shall be provided on the use of fire suppression systems and equipment.

**11.1.5\* Fire-Resistant Materials.** Materials adjacent to a laser that can be an ignition hazard shall be evaluated for their fire properties.

#### 11.2 Housekeeping.

**11.2.1** Laser equipment, systems, installation, and supporting materials and equipment shall be maintained in a clean, neat, and orderly condition.

**11.2.2** Electrical and mechanical ventilation equipment shall be maintained to remain safe and fully operational.

**11.2.3** The LSO shall ensure that the laser installation fully complies with the requirements of this and the referenced documents.

#### 11.3 Maintenance and Service.

**11.3.1** Maintenance shall be performed by trained personnel.

**11.3.2** Service shall be performed by trained personnel.

**11.3.3** Laser products certified by a manufacturer to be compliant with certain standards, such as the federal laser product performance standards of 21 CFR 1040, applicable at the date of manufacture, shall be maintained in compliance with such requirements.

**11.3.4** The LSO shall ensure that regular maintenance schedules for each type of laser are established.

**11.3.5** The LSO shall retain documentation of all maintenance and service performed.

**11.3.6** Maintenance checks shall include all supporting equipment.

**11.3.7** All electrical and mechanical systems shall be maintained in compliance with the documents listed in 11.1.1.

#### 11.4 Training and Education.

**11.4.1** A training program shall be established for staff members using and supporting the safe application of laser systems.

**11.4.2** All training shall follow OSHA guidelines; ANSI Z136.1, *Safe Use of Lasers*; ANSI Z136.3, *Safe Use of Lasers in Health Care Facilities*; and ANSI Z136.5, *Safe Use of Lasers in Educational Institutions*.

**11.4.3** The LSO shall ensure the necessary training records are maintained.

**11.4.4** New staff members shall be trained.

**11.4.5** When new lasers are introduced or existing laser systems are modified, staff members shall receive instruction on these systems.

**11.4.6** The LSO shall monitor compliance with all training and education requirements.

## Chapter 12 Emergency Preparedness

### 12.1 Pre-Fire Planning.

**12.1.1** Staff members shall be trained and knowledgeable in exit locations and emergency procedures, including use of fire extinguishers and laser shutdown procedures.

**12.1.2** Emergency services organizations shall be made aware of location and hazards of lasers.

**12.1.3** Facility emergency response personnel shall be familiar with emergency shutdown procedures for the laser(s).

### 12.2 Training.

**12.2.1** All staff members working with lasers shall receive instruction in the hazards of lasers and the use of fire-fighting equipment.

**12.2.2** Emergency drills shall be conducted no less than once per year.

**12.3 Fire Brigades.** Established industrial fire brigades shall receive training on the hazards of lasers, fire-fighting tactics, and emergency shutdown procedures, in conjunction with the requirements of NFPA 600.

### 12.4 Emergency Shutdown.

**12.4.1** A master emergency electrical shutdown switch that will immediately de-energize the laser shall be provided.

**12.4.2** The switch shall be located inside or outside of each room, at the facility's discretion.

**12.5 Fire Procedure.** The following actions shall be considered:

- (1) Alert others in the work area upon discovery of a fire.
- (2) Whoever is closest to a manual fire alarm pull station, activate the alarm to alert all building occupants and summon the industrial fire brigade or fire department.
- (3) Whoever is closest to the master emergency electrical shutdown switch, de-energize the laser.
- (4) Use a portable fire extinguisher to contain, control, and extinguish the fire if possible.
- (5) If the fire location involves medical oxidizing gases or industrial oxidizing gases, shut off the oxidizing gas supply.
- (6) Simultaneously, other staff members evacuate the area of hazard.
- (7) Close all doors in fire area.

## Annex A Explanatory Material

*Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.*

**A.3.3.2.1 Approved.** The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

**A.3.3.2.2 Authority Having Jurisdiction (AHJ).** The phrase “authority having jurisdiction,” or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

**A.3.3.2.4 Listed.** The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

**A.3.3.3.1 Accessible Emission Limit (AEL).** This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*, and 21 CFR 1040.10.

**A.3.3.3.2 Beam.** This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*.

**A.3.3.3.4 Continuous Wave (cw).** In this document, a laser operation with a continuous output for a period  $\geq 0.25$  seconds is regarded as a cw laser. This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*.

**A.3.3.3.5 Energy.** Energy content is commonly used to characterize the output from pulsed lasers, and is generally expressed in joules (J). This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*.

**A.3.3.3.6 Explosion.** An explosion can be accompanied by a shock wave or the disruption or enclosing of material or structures, or both. An explosion might result from chemical changes such as rapid oxidation, decomposition, or runaway polymerization (usually detonations); deflagration; or detonation.

**A.3.3.3.8 Flammable Liquid Storage Cabinet.** The cabinet should be constructed in accordance with NFPA 30. Some local jurisdictions require bottom-venting of flammable liquid storage cabinets. While this is not required by NFPA 30, some manufacturers provide plugged vent connections to accommodate these local jurisdictions.

**A.3.3.3.10 Flash Point.** See Annex E.

**A.3.3.3.11.3 Reactive Gas.** Reactive gases can also be corrosive.

**A.3.3.3.12 Hazardous Chemical.** For hazard ratings of many chemicals, see NFPA *Fire Protection Guide to Hazardous Materials*.

**A.3.3.3.14 Joule.** A joule is the heat produced when one ampere is passed through a resistance of one ohm for one second, or it is the work required to move a distance of one meter against a force of one newton. There are 4.184 joules in a calorie, and 1055 joules in a British thermal unit (Btu). A watt is a joule/second. [921, 2017]

**A.3.3.3.16 Laser.** This definition and definitions in 3.3.16.1 through 3.3.16.3 are extracted from ANSI Z136.1, *Safe Use of Lasers*, and 21 CFR 1040.10.

**A.3.3.3.17 Laser Safety Personnel (LSP).** This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*.

**A.3.3.3.18 Laser System.** This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*.

**A.3.3.3.22 Maintenance (Laser Products).** It does not include *operation* or *service* as defined in this document. This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*, and 21 CFR 1040.10.

**A.3.3.3.23 Maximum Allowable Working Pressure.** For a more complete definition, see Section VIII of the ASME *Boiler and Pressure Vessel Code*, Division 1, Appendix 3. [59A, 2019]

**A.3.3.3.24 Noncombustible.** Materials that are reported as passing ASTM E136 are considered noncombustible. (See NFPA 220.)

**A.3.3.3.25 Operation.** It does not include *maintenance* or *service* as defined in this document. This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*, and 21 CFR 1040.10.

**A.3.3.3.28 Plasma.** Very high temperatures are associated with laser-generated plasmas that can appear as sparks, plumes, or flames.

**A.3.3.3.31 Protective Housing.** The aperture through which the useful beam is emitted is not part of the protective housing. The protective housing can enclose associated optics and a workstation and should limit access to other associated radiant energy emissions and to electrical hazards associated with components and terminals. This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*, and 21 CFR 1040.10.

**A.3.3.3.32 Q-Switch.** This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*.

**A.3.3.3.33 Radiant Exposure.** This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*.

**A.3.3.3.35 Service (Laser Products).** It does not include *maintenance* or *operation* as defined in this document. This definition is extracted from ANSI Z136.1, *Safe Use of Lasers*, and 21 CFR 1040.10.

**A.5.1.1** Lower values can be possible, particularly in an oxygen-enriched atmosphere, depending on the thickness and the physical properties of the material. See NSBIR 81-2271 and ASTM STP822.

**A.5.1.2(3)** Very high repetition rates can produce ignition hazards similar to cw laser beams.

**A.5.1.4** Lasers in the lower power and energy levels of Class 3b are often incapable of being beam ignition hazards.

**A.6.3.1.2** Those personnel include the surgeon or physician using the laser, the laser safety officer, anesthesia personnel, nursing staff, and other health care personnel as appropriate.

**A.7.2.4** See Article 500 of *NFPA 70*.

**A.7.3** Materials to consider include thermal and acoustical insulation, laminates, hoses, filters, and coil forms. From a fire safety design perspective, materials that have low ignition potential and low rates of heat release if ignited are most desirable. Heat release rate for a material is expressed in terms of kilowatts released for each square meter of material burning and is related to the physical and chemical or combustion characteristics of that material.

ASTM E1354 is useful for evaluating candidate materials. It is recommended that the materials being evaluated be tested at two different levels of incident flux, a low level (25 kW/m<sup>2</sup> to 30 kW/m<sup>2</sup>) and a high level (55 kW/m<sup>2</sup> to 65 kW/m<sup>2</sup>). Most materials will have a higher rate of heat release at the high flux. The additional test at a high flux level provides an indication of the expected heat release rate in a well-developed fire in a confined space.

Materials that have the lowest heat release rate at the high flux and the longest ignition time at low flux should be selected. If several candidate materials have similar heat release and ignition characteristics, the material with the lowest smoke production should be considered.

**A.7.5.3** Significant particulate production can occur well in advance of smoldering or flaming fire. Increases in background particulate levels can indicate an incipient problem.

**A.8.4.1.2** See *NFPA 55* for additional information.

**A.8.4.3** Regulator diaphragm failures should be considered when locating a flammable gas regulator in an enclosed area.

**A.8.4.3.1** Standard gas regulators do not have these fittings and release supply gases through vent holes located in the bonnet in the event of a regulator diaphragm failure.

**A.9.3.3** Some gases can be incompatible with water. Water reactivity should be evaluated.

**A.9.4.2.4** A method for purging piping with inert gas is to have a series of evacuations followed by an inert gas fill.

**A.9.4.2.5.2** These types of fittings can trap contaminants and be difficult to purge.

**A.9.4.3.4** Standard gas regulators do not have these fittings and release supply gases through vent holes located in the bonnet in the event of a regulator diaphragm failure.

**A.10.1** Dye lasers normally use a lasing medium composed of a complex fluorescent organic dye dissolved in an organic solvent. Practically all solvents suitable for dye solutions are ignitable. Some dye solutions come premixed from the manu-

facturer, in which case efforts should be made to determine which solvent was used for the preparation.

**A.10.3.6** For example, nonpolar solvents flowing through plastic tubing can develop a static charge. As another example, a grounding wire should be incorporated into plastic tubing to dissipate static charge that can accumulate when nonpolar solvents flow through nonconducting tubing.

**A.10.8** See the *NFPA Fire Protection Handbook* for a list of liquids subject to self-heating and autoignition.

**A.11.1.5** Examples of fire properties to be evaluated include ignition, flame spread, and oxygen index.

A study on the flammability of surgical drapes has been described in Bauman, "Laser Drape Fires: How Much of a Risk?"

## Annex B Nature of Hazards

*This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.*

**B.1 Nature of Hazard.** A beam ignition hazard might exist during the use of a laser — for example, in a research, commercial, industrial, military, or health care facility.

## Annex C Education and Training

*This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.*

**C.1** The LSO (laser safety officer), laser users, and maintenance or service personnel should be trained in laser fire safety and in recognizing fire hazards associated with the use of lasers. This training should be updated at least annually and any time there are changes in the laser use that can present different fire safety concerns. The following issues should be addressed during the training:

- (1) Awareness of installed fire protection features in the facility and laser system
- (2) Preplanning for fires, involving the appropriate emergency response personnel such as fire department or plant brigade
- (3) Information on the location and method to shut off power, gases, and flammable liquids
- (4) Understanding the role of employees in the fire safety plan for the facility (For example, are they expected to extinguish incipient fire? If so, appropriate training should be provided.)
- (5) The safety hazards of the materials and procedures to which employees or emergency response personnel are exposed, with proper information and training provided

The following issues should be addressed during the training provided to health care facility laser users:

- (1) Health care workers using medical lasers should be educated as to the fire safety problems associated with lasers in the surgical suite.
- (2) General fire safety information can include an understanding of the classes of fires, extinguishing requirements of those classes of fires, and knowledge of the proper operation of handheld portable fire-fighting equipment.
- (3) Training on the hazards found in the surgical suite with regard to combustible substances, gases, and oxygen-

enriched atmospheres should be conducted on an annual basis.

- (4) Training on any changes in equipment or procedures that can affect fire safety should be addressed prior to the use of such equipment or procedures.
- (5) To reduce the incidence of fire, training on special hazards associated with the operative site when using a medical laser should be routinely reviewed and updated as new products or equipment are brought into the arena.
- (6) Fire safety training can include the following:
  - (a) The action(s) to be taken if drapes are burning
  - (b) The responsibilities of the anesthesiologist
  - (c) Responsibilities of each individual in the surgical suite if a patient fire develops
- (7) Training on the facility's fire safety plan, location of fire alarms, location of fire-fighting equipment, and emergency evacuation should be conducted on an ongoing basis.

#### Annex D Classification of Lasers

*This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.*

**D.1** This annex contains a brief explanation of the classification schemes for lasers. It is intended only to give an overview. The reader should consult the normative references in Chapter 4 to obtain detailed information about the laser hazard classes.

The laser safety standards in Chapter 4 have been in existence for approximately 30 years. These standards are aimed at preventing or reducing personal injuries resulting from exposure to hazardous levels of laser radiation. These standards operate by establishing hazard classes for lasers and by imposing equipment, informational, and administrative control measures that are appropriate for the degree of hazard.

Although the hazard classes were developed with respect to the potential for causing biological injury, they can also be useful as indicators of the ignition potential of the lasers. The processes by which lasers can cause biological injury are the same as those by which they can cause ignition. The big difference is that for biological injury from lasers in the visible and near-infrared spectral regions, the most sensitive organ is the eye because of the ability to focus laser spots on the retina. Although there are differences between the classes in the standards, there are more similarities than differences. There are four general classes: 1, 2, 3, and 4 (or I, II, III, and IV). With the exception of Class 4, the classes have limits, accessible emission limits (AEL), that consider power, emission duration, and beam propagation properties. Lasers are classified according to the level of laser radiation that is accessible during "operation," that is, when the laser is performing its intended function.

Class 1 (I) lasers either emit radiation at levels so low that they are not recognized to be capable of producing an injury or are more hazardous but are safely contained within a protective housing. Class 1 lasers can emit radiation anywhere in the optical spectrum with wavelengths between 180 nanometers and 1 meter. Some Class 1 lasers, however, contain embedded lasers of higher classes. An example would be Class 4 lasers contained within Class 1 laser machine tools.

Class 2 (II) lasers emit in the visible spectrum, between 400 and 700 nanometers, but at levels for which, although recognized to be hazardous to the eyes, a person's aversion to looking into a bright light source is sufficient to avoid an injury to the retina of the eye.

IEC 60825-1, *Safety of laser products — Part 1: Equipment classification, requirements and user's guide*, has, in its latest version, two subclasses, Classes 1M and 2M. These M classes mean that a biological hazard could be created for Class 1M, or increased for Class 2M, if a collecting optical instrument such as a telescope or loupe were used to view the laser radiation. It is likely that the ANSI Z136 Committee and the U.S. Food and Drug Administration (FDA) will adopt a similar classification scheme in the near future.

Class 3a lasers (Class IIIa lasers in 21 CFR 1040.10 and 1040.11 and Class 3R lasers in IEC 60825-1) are less than 5 times the level of either Class 1 or Class 2. They are recognized to be hazardous, but the degree of risk of a radiation injury is considered to be too low to justify severe control measures.

In addition to the biological hazard, Classes 3b and 4 possess potential for ignition.

Class 3b (IIIb) has a large range. At the low end, Class 3b lasers are considered to have a reasonable potential for retinal injury and at the high end to be a skin hazard as well.

Class 4 (IV) has no upper limit. Class 4 lasers are considered to be hazardous not only by direct exposure but also by exposure to laser radiation scattered by diffuse targets.

Since the laser hazard classes are already in place, the ignition potential of the classes can be considered. The potential for ignition involves many factors, including the following:

- (1) Power or energy
- (2) Irradiance or radiant exposure
- (3) Size of the laser spot on the target
- (4) Duration of exposure
- (5) Environmental factors such as the presence of fabric drapes, volatile solvents, or oxygen-enriched atmospheres (OEA) in health care facilities
- (6) Thickness of the target material
- (7) Thermal conductivity of the target material

A general assessment of the ignition potential for the classes is given in Table D.1.

**Table D.1 Laser Ignition Potential**

Classification	Examples	Ignition Potential	Remarks
1, 2 (I, II)	CD players, laser printers, fiber-optic telecommunications, bar code scanners	Negligible	Not considered in NFPA 115
1M, 2M	Distance-measuring instruments, police radar, infrared telecom	Conceivable but improbable	Unlikely that one would position a lens in front of such a laser and focus it to cause ignition; not considered in NFPA 115
3a (IIIa), 3R	Laser pointers, laboratory lasers	Possible under extreme circumstances	Necessitates a deliberate attempt to cause ignition; not considered in NFPA 115
3b (IIIb), 3B	Industrial machine vision, laboratory lasers, medical lasers (e.g., for tattoo removal)	Possible at the high end of the class	Focusing optics or an irradiance $>0.5 \text{ W/cm}^2$ ; requirements in NFPA 115
4 (IV)	Surgical lasers, industrial lasers, commercial light shows, laboratory lasers	Probable for highly absorbent materials	Requirements in NFPA 115

### Annex E Flash Point

*This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.*

**E.1** The following text is extracted from the 2018 edition of NFPA 30.

*Flash point* is a direct measure of a liquid's ability to emit flammable vapors. The lower the flash point, the greater the risk of fire. Flash point is determined using one of several different test procedures and apparatus that are specified in Section 4.4 of NFPA 30.

A liquid that has a flash point at or below ambient temperature is easy to ignite and will burn quickly. On ignition, the spread of flame over the surface of such a liquid will be rapid, because it is not necessary for the fire to expend energy heating the liquid to generate more vapor. Gasoline is a familiar example. A liquid with a flash point above ambient temperature presents less risk because it must be heated to generate enough vapor to become ignitable; it is more difficult to ignite and presents less potential for the generation and spread of vapor. A common example is home heating oil (Fuel Oil No. 2). Home heating oil must be atomized to a fine mist in order for it to be easily ignited.

Certain solutions of liquids in water exhibit a flash point using the standard closed-cup test procedures but will not burn and could even extinguish a fire. To assist identifying such solutions, the following standards are helpful:

- (1) ASTM D4207, *Standard Test Method for Sustained Burning of Low Viscosity Liquid Mixtures by the Wick Test*
- (2) ASTM D4206, *Standard Test Method for Sustained Burning of Liquid Mixtures Using the Small Scale Open-Cup Apparatus*

Liquid mixtures that do not sustain combustion for a specified time at a specified temperature are considered to be noncombustible. The tests described in the references listed in (1) and (2) provide additional data for determining proper storage and handling of such mixtures. In a confined space, such mixtures could still create an ignitable vapor-air mixture, depending on the amount of flammable liquid in the mixture and the quantity of the spill.

Related to the flash point is the *fire point*. The fire point of a liquid is the temperature at which ignition of vapors will result in continued burning. As the term *flash point* suggests, the vapors generated at that temperature will flash but will not necessarily continue to burn. The difference between flash point and fire point has some significance when conducting flash point tests [see 9.1.4 of NFPA 30 for references to ASTM D92, *Standard Test Method for Flash and Fire Points by Cleveland Open Cup*, and 49 CFR (U.S. Department of Transportation *Hazardous Materials Regulations*), *Method of Testing for Sustained Combustibility*]. However, a closed-cup flash point is used to classify the liquid and characterize its hazard.

For more information, see ASTM E502, *Standard Test Method for Selection and Use of ASTM Standards for the Determination of Flash Point of Chemicals by Closed Cup Methods*, and the *ASTM Manual on Flash Point Standards and Their Use*.

### Annex F Informational References

**F.1 Referenced Publications.** The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not part of the requirements of this document unless also listed in Chapter 2 for other reasons.

**F.1.1 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 30, *Flammable and Combustible Liquids Code*, 2018 edition.

NFPA 55, *Compressed Gases and Cryogenic Fluids Code*, 2020 edition.

NFPA 70, *National Electrical Code*, 2020 edition.

NFPA 220, *Standard on Types of Building Construction*, 2018 edition.

NFPA *Fire Protection Guide to Hazardous Materials*, 14th edition, 2010.

NFPA *Fire Protection Handbook*<sup>®</sup>, 20th edition, 2008.

### F.1.2 Other Publications.

**F.1.2.1 ANSI Publications.** American National Standards Institute, Inc., 25 West 43rd Street, 4th Floor, New York, NY 10036.

ANSI Z136.1, *Safe Use of Lasers*, 2014.

**F.1.2.2 ASME Publications.** American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990.

*Boiler and Pressure Vessel Code*, 2013.

**F.1.2.3 ASTM Publications.** ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D92, *Standard Test Method for Flash and Fire Points by Cleveland Open Cup*, 2016.

ASTM D4206, *Standard Test Method for Sustained Burning of Liquid Mixtures Using the Small Scale Open-Cup Apparatus*, 1996 (reapproved 2013).

ASTM D4207, *Standard Test Method for Sustained Burning of Low Viscosity Liquid Mixtures by the Wick Test*, 1991 (withdrawn 1998).

ASTM E136, *Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750 Degrees C*, 2016.

ASTM E502, *Standard Test Method for Selection and Use of ASTM Standards for the Determination of Flash Point of Chemicals by Closed Cup Methods*, 2007 (reapproved 2013).

ASTM E1354, *Standard Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter*, 2017.

ASTM STP882, Quintiere, J. G., and Harkleroad, M. T., "New Concepts for Measuring Flame Spread Properties," *Fire Safety: Science and Engineering*, pp. 239–269, 1985.

*ASTM Manual on Flash Point Standards and Their Use*, 1992.

**▲ F.1.2.4 IEC Publications.** International Electrotechnical Commission. Available from American National Standards Institute, 25 West 43rd Street, 4th Floor, New York, NY 10036, U.S. National Committee for the IEC ([www.ansi.org](http://www.ansi.org)).

IEC 60825-1, *Safety of laser products — Part 1: Equipment classification and requirements*, 2014.

**F.1.2.5 NIST Publications.** National Institute of Standards and Technology, 100 Bureau Drive, Gaithersburg, MD 20899-1070.

NSBIR 81-2271, Babrauskas, V., "Will the Second Item Ignite?" 1982.

**F.1.2.6 U.S. Government Publications.** U.S. Government Publishing Office, Washington, DC 20402.

Title 21, Code of Federal Regulations, Part 1040, "Performance Standards for Light-Emitting Products."

Title 49, Code of Federal Regulations.

### F.1.2.7 Additional Publications.

Bauman, N., "Laser Drape Fires: How Much of a Risk?" *Laser Medicine and Surgery News and Advances*, Vol. 7, No. 4, August 1989.

**F.2 Informational References.** The following documents or portions thereof are listed here as informational resources only. They are not a part of the requirements of this document.

**F.2.1 ASTM Publications.** ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D56, *Standard Test Method for Flash Point by the Tag Closed Tester*, 2016.

ASTM D93, *Standard Test Method for Flash Point by the Pensky-Martens Closed Tester*, 2016.

ASTM D3278, *Standard Test Methods for Flash Point of Liquids by Small Scale Closed-Cup Apparatus*, 1996 (reapproved 2011).

ASTM D3828, *Standard Test Methods for Flash Point by Small Scale Closed Tester*, 2016.

### F.2.2 Published Articles on Fires Involving Lasers and Related Equipment.

Bean, A. K., MD, and Ceilley, R.I., MD, "Reducing Fire Risks of the Flashlamp Pumped 585-nm Pulse Dye Laser," *Journal of Dermatologic Surgery and Oncology*, Vol. 20, p. 224, 1994.

Brodman, M., MD, et al., "Operating Room Personnel Morbidity from Carbon Dioxide Laser Use During Preceptor Surgery," *Obstetrics and Gynecology*, Vol. 81, pp. 607–9, 1993.

Domin, M. A., "Safety Precautions for Laser Surgery," *Journal of Healthcare Material Management*, Vol. 9, No. 5, June 1991.

Jacobson, E., "New Hospital Hazards: How to Protect Yourself," *American Journal of Nursing*, February 1990.

Lobraico, R. V., MD, "Laser Safety in Health Care Facilities: an Overview," *American College of Surgeons Bulletin*, Vol. 76, No. 8, pp. 17–22, August 1991.

Maley, R. A., and Harding, G., "Controlling Risks in the Use of Lasers," *Journal of Healthcare Risk Management*, Vol. 13, No. 1, Winter 1993.

Mowrer, F. W., and Ashman, M. N., "Flammability of Surgical Drapes," Report No. FP93-01, April 9, 1993 (available from F. W. Mowrer, Dept. of Fire Protection Engineering, University of Maryland, College Park, MD 20742).

Ossof, R. H., DMD, MD, and Kaplan, M.S., MD, "Safe Instrumentation in Laser Surgery," *Otolaryngology, Head & Neck Surgery*, Vol. 92, No. 6, December 1984.

Rupke, G., RN, "Vigilance, Education Are Keys to Overcoming Laser Safety Complacency," *AORN Journal*, Vol. 56, No. 3, p. 523, September 1992.

"Safety Standards to Prevent Laser Burns," *American Journal of Nursing*, Vol. 89, No. 4, April 1989.

Smalley, P. J., RN, "Clinical Laser Safety Issues Survey," *Journal of Laser Applications*, Winter 1991.

Wagner, M., "Accidents Detract from Laser's Potential," *Modern Healthcare*, March 25, 1991.

### F.3 References for Extracts in Informational Sections.

NFPA 30, *Flammable and Combustible Liquids Code*, 2018 edition.

NFPA 59A, *Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)*, 2019 edition.

NFPA 921, *Guide for Fire and Explosion Investigations*, 2017 edition.

## Index

Copyright © 2019 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

- |   |   |
|---|---|
| <p style="text-align: center;"><b>-A-</b></p> <p><b>Accessible Emission Limit (AEL)</b><br/>Definition, 3.3.1, A.3.3.1</p> <p><b>Administration, Chap. 1</b><br/>Application, 1.3<br/>Equivalency, 1.5<br/>Interface with Existing Codes and Standards, 1.6<br/>Purpose, 1.2<br/>Retroactivity, 1.4<br/>Scope, 1.1</p> <p><b>Approved</b><br/>Definition, 3.2.1, A.3.2.1</p> <p><b>Authority Having Jurisdiction (AHJ)</b><br/>Definition, 3.2.2, A.3.2.2</p> <p style="text-align: center;"><b>-B-</b></p> <p><b>Beam</b><br/>Definition, 3.3.2, A.3.3.2</p> <p><b>Beam Intensity Profile (Irradiance Distribution)</b><br/>Definition, 3.3.3</p> <p style="text-align: center;"><b>-C-</b></p> <p><b>Classification of Lasers, Annex D</b></p> <p><b>Classification of Lasers, Chap. 4</b><br/>Application of Requirements, 4.2<br/>Classification Methods, 4.1</p> <p><b>Continuous Wave (cw)</b><br/>Definition, 3.3.4, A.3.3.4</p> <p style="text-align: center;"><b>-D-</b></p> <p><b>Definitions, Chap. 3</b></p> <p style="text-align: center;"><b>-E-</b></p> <p><b>Education and Training, Annex C</b></p> <p><b>Emergency Preparedness, Chap. 12</b><br/>Emergency Shutdown, 12.4<br/>Fire Brigades, 12.3<br/>Fire Procedure, 12.5<br/>Pre-Fire Planning, 12.1<br/>Training, 12.2</p> <p><b>Energy</b><br/>Definition, 3.3.5, A.3.3.5</p> <p><b>Evaluation of Laser Beam Ignition Potential, Chap. 5</b><br/>Factors Affecting Ignition Potential, 5.2<br/>General, 5.1</p> <p><b>Explanatory Material, Annex A</b></p> <p><b>Explosion</b><br/>Definition, 3.3.6, A.3.3.6</p> | <p style="text-align: center;"><b>-F-</b></p> <p><b>Facility Fire Brigade</b><br/>Definition, 3.3.7</p> <p><b>Fire Safety Requirements for Laser Equipment, Chap. 7</b><br/>Alarms and Controls, 7.5<br/>Circuits, 7.5.1<br/>Coolants and Ignitable Liquids, 7.5.2<br/>Monitors, 7.5.3, A.7.5.3<br/>Performance Monitoring, 7.5.4<br/>General, 7.1<br/>Laser Equipment Employing Ignitable Liquids or Flammable Gases, 7.2<br/>Tubing, 7.2.5<br/>Laser Equipment Ventilation, 7.4<br/>Manuals and Training, 7.6<br/>Materials of Construction, 7.3, A.7.3</p> <p><b>Flammable Gases, Chap. 8</b><br/>Electrical Requirements, 8.5<br/>Facilities and Equipment, 8.4<br/>General, 8.4.1<br/>Exhaust Vents, 8.4.1.4<br/>Flammable Gas Supplies, 8.4.1.3<br/>Piping, 8.4.2<br/>Regulators, 8.4.3, A.8.4.3<br/>Flow Control, 8.4.3.3<br/>Fire Safety, 8.3<br/>General, 8.1<br/>Training, 8.6<br/>Work Practices, 8.2</p> <p><b>Flammable Liquid Storage Cabinet</b><br/>Definition, 3.3.8, A.3.3.8</p> <p><b>Flammable Vapors</b><br/>Definition, 3.3.9</p> <p><b>Flash Point, Annex E</b></p> <p><b>Flash Point</b><br/>Definition, 3.3.10, A.3.3.10</p> <p style="text-align: center;"><b>-G-</b></p> <p><b>Gas</b><br/>Compressed Gas<br/>Definition, 3.3.11.1<br/>Definition, 3.3.11<br/>Flammable Gas<br/>Definition, 3.3.11.2<br/>Reactive Gas<br/>Definition, 3.3.11.3, A.3.3.11.3</p> <p style="text-align: center;"><b>-H-</b></p> <p><b>Hazardous Chemical</b><br/>Definition, 3.3.12, A.3.3.12</p> |
|---|---|



**-I-****Ignitable Liquids Used in Laser Systems**, Chap. 10

- Electrical Requirements, 10.5
- Facilities and Equipment, 10.4
  - Circulating Systems, 10.4.4
  - Ignitable Liquid Dye Work Area, 10.4.1
- Fire Safety, 10.3
  - Cabinets, 10.3.4
  - Waste Containment, 10.3.3
- General, 10.1, A.10.1
- Large-Volume Ignitable Liquid Systems, 10.6
  - Building Construction, 10.6.8
  - Remote Shutdown, 10.6.7
- Maintenance, 10.10
- Spill Cleanup, 10.7
- Training, 10.9
- Waste Disposal, 10.8, A.10.8
- Work Practices, 10.2
  - Flammable Liquids, 10.2.3

**Informational References**, Annex F**Irradiance**

- Definition, 3.3.13

**-J-****Joule**

- Definition, 3.3.14, A.3.3.14

**-L-****Labeled**

- Definition, 3.2.3

**Laboratory Apparatus**

- Definition, 3.3.15

**Laser**

- Definition, 3.3.16, A.3.3.16
- Embedded Laser
  - Definition, 3.3.16.1
- Pulsed Laser
  - Definition, 3.3.16.2
- Q-Switched Laser
  - Definition, 3.3.16.3

**Laser Beam Ignition**, Chap. 6

- Before Using Laser, 6.2
  - Beam Alignment, 6.2.1
  - Beam Stop Materials, 6.2.2
- Education, 6.3
  - Health Care, 6.3.1
  - Other, 6.3.2
- Facility, 6.4
  - Flammable and Combustible Conditions, 6.4.3
  - Other, 6.4.2
- General, 6.1

**Laser Safety Personnel (LSP)**

- Definition, 3.3.17, A.3.3.17

**Laser System**

- Definition, 3.3.18, A.3.3.18

**Lecture Bottle**

- Definition, 3.3.19

**Liquid**

- Combustible Liquid
  - Definition, 3.3.20.1
- Definition, 3.3.20
- Flammable Liquid
  - Definition, 3.3.20.2
- Ignitable Liquid
  - Definition, 3.3.20.3

**Listed**

- Definition, 3.2.4, A.3.2.4

**Lower Explosive Limit or Lower Flammable Limit**

- Definition, 3.3.21

**-M-****Maintenance (Laser Products)**

- Definition, 3.3.22, A.3.3.22

**Maximum Allowable Working Pressure**

- Definition, 3.3.23, A.3.3.23

**-N-****Nature of Hazards**, Annex B

- Nature of Hazard, B.1

**Noncombustible**

- Definition, 3.3.24, A.3.3.24

**-O-****Operation**

- Definition, 3.3.25, A.3.3.25

**Operations/Administration**, Chap. 11

- Housekeeping, 11.2
- Maintenance and Service, 11.3
- Safety Operations and Administration, 11.1
  - Fire Suppression, 11.1.4
  - Fire-Resistant Materials, 11.1.5, A.11.1.5
  - Laser Modifications, 11.1.3
  - Laser Safety Officer (LSO), 11.1.2
  - Lasers, 11.1.1
- Training and Education, 11.4

**Oxidizing Material**

- Definition, 3.3.26

**Oxygen-Enriched Atmosphere (OEA)**

- Definition, 3.3.27

**-P-****Plasma**

- Definition, 3.3.28, A.3.3.28

**Power**

- Definition, 3.3.29

**Proper(ly)**

- Definition, 3.3.30

**Protective Housing**

- Definition, 3.3.31, A.3.3.31

**-Q-****Q-Switch**

- Definition, 3.3.32, A.3.3.32

**-R-****Radiant Exposure**

Definition, 3.3.33, A.3.3.33

**Reactive Gases**, Chap. 9

Electrical Requirements, 9.5

Facilities and Equipment, 9.4

Flow Control, 9.4.4

General, 9.4.1

Exhaust, 9.4.1.5

Piping, 9.4.2

Fittings, 9.4.2.5

Regulators, 9.4.3

Fire Safety, 9.3

Gas Cabinets, 9.3.3, A.9.3.3

Gas Quantity and Concentration, 9.3.4

General, 9.1

Training, 9.6

Work Practices, 9.2

Maintenance, 9.2.6

**Referenced Publications**, Chap. 2**-S-****Safety Factor**

Definition, 3.3.34

**Service (Laser Products)**

Definition, 3.3.35, A.3.3.35

**Shall**

Definition, 3.2.5

**Should**

Definition, 3.2.6

**Standard**

Definition, 3.2.7

**-W-****Watt (W)**

Definition, 3.3.36

## Sequence of Events for the Standards Development Process

Once the current edition is published, a Standard is opened for Public Input.

### Step 1 – Input Stage

- Input accepted from the public or other committees for consideration to develop the First Draft
- Technical Committee holds First Draft Meeting to revise Standard (23 weeks); Technical Committee(s) with Correlating Committee (10 weeks)
- Technical Committee ballots on First Draft (12 weeks); Technical Committee(s) with Correlating Committee (11 weeks)
- Correlating Committee First Draft Meeting (9 weeks)
- Correlating Committee ballots on First Draft (5 weeks)
- First Draft Report posted on the document information page

### Step 2 – Comment Stage

- Public Comments accepted on First Draft (10 weeks) following posting of First Draft Report
- If Standard does not receive Public Comments and the Technical Committee chooses not to hold a Second Draft meeting, the Standard becomes a Consent Standard and is sent directly to the Standards Council for issuance (see Step 4) or
- Technical Committee holds Second Draft Meeting (21 weeks); Technical Committee(s) with Correlating Committee (7 weeks)
- Technical Committee ballots on Second Draft (11 weeks); Technical Committee(s) with Correlating Committee (10 weeks)
- Correlating Committee Second Draft Meeting (9 weeks)
- Correlating Committee ballots on Second Draft (8 weeks)
- Second Draft Report posted on the document information page

### Step 3 – NFPA Technical Meeting

- Notice of Intent to Make a Motion (NITMAM) accepted (5 weeks) following the posting of Second Draft Report
- NITMAMs are reviewed and valid motions are certified by the Motions Committee for presentation at the NFPA Technical Meeting
- NFPA membership meets each June at the NFPA Technical Meeting to act on Standards with “Certified Amending Motions” (certified NITMAMs)
- Committee(s) vote on any successful amendments to the Technical Committee Reports made by the NFPA membership at the NFPA Technical Meeting

### Step 4 – Council Appeals and Issuance of Standard

- Notification of intent to file an appeal to the Standards Council on Technical Meeting action must be filed within 20 days of the NFPA Technical Meeting
- Standards Council decides, based on all evidence, whether to issue the standard or to take other action

#### Notes:

1. Time periods are approximate; refer to published schedules for actual dates.
2. Annual revision cycle documents with certified amending motions take approximately 101 weeks to complete.
3. Fall revision cycle documents receiving certified amending motions take approximately 141 weeks to complete.

## Committee Membership Classifications<sup>1,2,3,4</sup>

The following classifications apply to Committee members and represent their principal interest in the activity of the Committee.

1. M *Manufacturer*: A representative of a maker or marketer of a product, assembly, or system, or portion thereof, that is affected by the standard.
2. U *User*: A representative of an entity that is subject to the provisions of the standard or that voluntarily uses the standard.
3. IM *Installer/Maintainer*: A representative of an entity that is in the business of installing or maintaining a product, assembly, or system affected by the standard.
4. L *Labor*: A labor representative or employee concerned with safety in the workplace.
5. RT *Applied Research/Testing Laboratory*: A representative of an independent testing laboratory or independent applied research organization that promulgates and/or enforces standards.
6. E *Enforcing Authority*: A representative of an agency or an organization that promulgates and/or enforces standards.
7. I *Insurance*: A representative of an insurance company, broker, agent, bureau, or inspection agency.
8. C *Consumer*: A person who is or represents the ultimate purchaser of a product, system, or service affected by the standard, but who is not included in (2).
9. SE *Special Expert*: A person not representing (1) through (8) and who has special expertise in the scope of the standard or portion thereof.

NOTE 1: “Standard” connotes code, standard, recommended practice, or guide.

NOTE 2: A representative includes an employee.

NOTE 3: While these classifications will be used by the Standards Council to achieve a balance for Technical Committees, the Standards Council may determine that new classifications of member or unique interests need representation in order to foster the best possible Committee deliberations on any project. In this connection, the Standards Council may make such appointments as it deems appropriate in the public interest, such as the classification of “Utilities” in the National Electrical Code Committee.

NOTE 4: Representatives of subsidiaries of any group are generally considered to have the same classification as the parent organization.

## ***Submitting Public Input / Public Comment Through the Online Submission System***

Following publication of the current edition of an NFPA standard, the development of the next edition begins and the standard is open for Public Input.

### **Submit a Public Input**

NFPA accepts Public Input on documents through our online submission system at [www.nfpa.org](http://www.nfpa.org). To use the online submission system:

- Choose a document from the List of NFPA codes & standards or filter by Development Stage for “codes accepting public input.”
- Once you are on the document page, select the “Next Edition” tab.
- Choose the link “The next edition of this standard is now open for Public Input.” You will be asked to sign in or create a free online account with NFPA before using this system.
- Follow the online instructions to submit your Public Input (see [www.nfpa.org/publicinput](http://www.nfpa.org/publicinput) for detailed instructions).
- Once a Public Input is saved or submitted in the system, it can be located on the “My Profile” page by selecting the “My Public Inputs/Comments/NITMAMs” section.

### **Submit a Public Comment**

Once the First Draft Report becomes available there is a Public Comment period. Any objections or further related changes to the content of the First Draft must be submitted at the Comment Stage. To submit a Public Comment follow the same steps as previously explained for the submission of Public Input.

### **Other Resources Available on the Document Information Pages**

**Header:** View document title and scope, access to our codes and standards or NFCSS subscription, and sign up to receive email alerts.



Research current and previous edition information.



Follow the committee’s progress in the processing of a standard in its next revision cycle.



View current committee rosters or apply to a committee.



For members, officials, and AHJs to submit standards questions to NFPA staff. Our Technical Questions Service provides a convenient way to receive timely and consistent technical assistance when you need to know more about NFPA standards relevant to your work.



Provides links to available articles and research and statistical reports related to our standards.



Discover and purchase the latest products and training.



View related publications, training, and other resources available for purchase.

## ***Information on the NFPA Standards Development Process***

**I. Applicable Regulations.** The primary rules governing the processing of NFPA standards (codes, standards, recommended practices, and guides) are the NFPA *Regulations Governing the Development of NFPA Standards (Regs)*. Other applicable rules include NFPA *Bylaws*, NFPA *Technical Meeting Convention Rules*, NFPA *Guide for the Conduct of Participants in the NFPA Standards Development Process*, and the NFPA *Regulations Governing Petitions to the Board of Directors from Decisions of the Standards Council*. Most of these rules and regulations are contained in the *NFPA Standards Directory*. For copies of the *Directory*, contact Codes and Standards Administration at NFPA headquarters; all these documents are also available on the NFPA website at “[www.nfpa.org/regs](http://www.nfpa.org/regs).”

The following is general information on the NFPA process. All participants, however, should refer to the actual rules and regulations for a full understanding of this process and for the criteria that govern participation.

**II. Technical Committee Report.** The Technical Committee Report is defined as “the Report of the responsible Committee(s), in accordance with the Regulations, in preparation of a new or revised NFPA Standard.” The Technical Committee Report is in two parts and consists of the First Draft Report and the Second Draft Report. (See *Regs* at Section 1.4.)

**III. Step 1: First Draft Report.** The First Draft Report is defined as “Part one of the Technical Committee Report, which documents the Input Stage.” The First Draft Report consists of the First Draft, Public Input, Committee Input, Committee and Correlating Committee Statements, Correlating Notes, and Ballot Statements. (See *Regs* at 4.2.5.2 and Section 4.3.) Any objection to an action in the First Draft Report must be raised through the filing of an appropriate Comment for consideration in the Second Draft Report or the objection will be considered resolved. [See *Regs* at 4.3.1(b).]

**IV. Step 2: Second Draft Report.** The Second Draft Report is defined as “Part two of the Technical Committee Report, which documents the Comment Stage.” The Second Draft Report consists of the Second Draft, Public Comments with corresponding Committee Actions and Committee Statements, Correlating Notes and their respective Committee Statements, Committee Comments, Correlating Revisions, and Ballot Statements. (See *Regs* at 4.2.5.2 and Section 4.4.) The First Draft Report and the Second Draft Report together constitute the Technical Committee Report. Any outstanding objection following the Second Draft Report must be raised through an appropriate Amending Motion at the NFPA Technical Meeting or the objection will be considered resolved. [See *Regs* at 4.4.1(b).]

**V. Step 3a: Action at NFPA Technical Meeting.** Following the publication of the Second Draft Report, there is a period during which those wishing to make proper Amending Motions on the Technical Committee Reports must signal their intention by submitting a Notice of Intent to Make a Motion (NITMAM). (See *Regs* at 4.5.2.) Standards that receive notice of proper Amending Motions (Certified Amending Motions) will be presented for action at the annual June NFPA Technical Meeting. At the meeting, the NFPA membership can consider and act on these Certified Amending Motions as well as Follow-up Amending Motions, that is, motions that become necessary as a result of a previous successful Amending Motion. (See 4.5.3.2 through 4.5.3.6 and Table 1, Columns 1-3 of *Regs* for a summary of the available Amending Motions and who may make them.) Any outstanding objection following action at an NFPA Technical Meeting (and any further Technical Committee consideration following successful Amending Motions, see *Regs* at 4.5.3.7 through 4.6.5) must be raised through an appeal to the Standards Council or it will be considered to be resolved.

**VI. Step 3b: Documents Forwarded Directly to the Council.** Where no NITMAM is received and certified in accordance with the *Technical Meeting Convention Rules*, the standard is forwarded directly to the Standards Council for action on issuance. Objections are deemed to be resolved for these documents. (See *Regs* at 4.5.2.5.)

**VII. Step 4a: Council Appeals.** Anyone can appeal to the Standards Council concerning procedural or substantive matters related to the development, content, or issuance of any document of the NFPA or on matters within the purview of the authority of the Council, as established by the *Bylaws* and as determined by the Board of Directors. Such appeals must be in written form and filed with the Secretary of the Standards Council (see *Regs* at Section 1.6). Time constraints for filing an appeal must be in accordance with 1.6.2 of the *Regs*. Objections are deemed to be resolved if not pursued at this level.

**VIII. Step 4b: Document Issuance.** The Standards Council is the issuer of all documents (see Article 8 of *Bylaws*). The Council acts on the issuance of a document presented for action at an NFPA Technical Meeting within 75 days from the date of the recommendation from the NFPA Technical Meeting, unless this period is extended by the Council (see *Regs* at 4.7.2). For documents forwarded directly to the Standards Council, the Council acts on the issuance of the document at its next scheduled meeting, or at such other meeting as the Council may determine (see *Regs* at 4.5.2.5 and 4.7.4).

**IX. Petitions to the Board of Directors.** The Standards Council has been delegated the responsibility for the administration of the codes and standards development process and the issuance of documents. However, where extraordinary circumstances requiring the intervention of the Board of Directors exist, the Board of Directors may take any action necessary to fulfill its obligations to preserve the integrity of the codes and standards development process and to protect the interests of the NFPA. The rules for petitioning the Board of Directors can be found in the *Regulations Governing Petitions to the Board of Directors from Decisions of the Standards Council* and in Section 1.7 of the *Regs*.

**X. For More Information.** The program for the NFPA Technical Meeting (as well as the NFPA website as information becomes available) should be consulted for the date on which each report scheduled for consideration at the meeting will be presented. To view the First Draft Report and Second Draft Report as well as information on NFPA rules and for up-to-date information on schedules and deadlines for processing NFPA documents, check the NFPA website ([www.nfpa.org/docinfo](http://www.nfpa.org/docinfo)) or contact NFPA Codes & Standards Administration at (617) 984-7246.

# Xchange

The Online Community of the  
National Fire Protection Association®



## CONNECT WITH YOUR PEERS FROM AROUND THE WORLD



**NFPA® Xchange™ is an online forum for finding and sharing knowledge among an open community of professionals worldwide.**

This educational tool and job aid allows you to explore content relevant to you, participate in discussions with peers and industry leaders, ask and answer questions, and receive expert advice.

Membership to NFPA Xchange is free and provides access to:

- An active community of more than **50,000 professionals collaborating** in a single place
- Insights and information on **trending topics, emerging issues, and new technologies**
- **Blogs and webinars for learning on-the-job skills, and forums** for submitting queries to be answered by peers and NFPA® technical staff
- **Job board for posting open positions and discovering employment opportunities** from NFPA and partner organizations
- **A robust collection of previously asked questions and subject matter** in a searchable database accessible anywhere, anytime, from any device

Have the resources you need by your side at all times. NFPA Xchange provides the knowledge and support to help you do your job better and help protect lives and property. **Join the conversation today!**

Join now for free at [nfpa.org/xchange-community](https://nfpa.org/xchange-community)



IT'S A BIG WORLD.  
LET'S PROTECT IT TOGETHER.®

